
Name of Contractor

Signature acknowledging receipt of addendum

Detach cover and email to City of Galt Clerk's Office as Acknowledgment of Receipt of Addendum
Email: clerk@ci.galt.ca.us

OR

Acknowledge Addenda on City of Galt Bid Form

ADDENDUM NUMBER 2
for

Firing Range Block Wall Extension Project
CIP # 421A

City of Galt
Galt, California


August 14, 2019

This Addendum changes the project specifications and drawings dated July 15, 2019. Unchanged portions of the drawings and specifications remain in effect. Bidders shall acknowledge receipt of this Addendum by detaching and returning this acknowledgment form OR indicating it on their bid form.

Note: This Addendum consists of two (2) Total Sheets:

- Addendum No. 2 Cover
- Clarification and Revision sheet

Contractor shall contact City immediately if all pages are not received.



Mark A. Clarkson, P.E.
Deputy Public Works Director


Date

Clarification and Revisions

Item

1	REQUEST FOR CLARIFICATION: Question – What is required for SWPPP? Answer – Two stabilized construction site access, fiber rolls on west side of berm, silt fence on north side of berm, concrete washout, blanket/mat on berm when berm height reaches 4 feet.
2	REQUEST FOR CLARIFICATION: Question – Must borrow field (field 4) be hydroseeded? Answer – No, only hydroseed berm after construction.
3	REQUEST FOR CLARIFICATION: Question – Is a City Building Permit Required? Answer – Yes contractor is required to pull a building permit and the fee will be waived.